	SUTANIMAL CONTROL	ENVIRONMENTAL HEALTH DIVISION				E TO OF CAL	
	CHERGENET MEDICAL ENVIRONMENTAL HEALTH FURLIC REALTH COLUMITY OF WENT	2700 M STREET, SUITE VOICE: (661) 321 Web: www.co.kern.ca	-3000 FAX: (661) 862-8701	70	OFCALING	
MATTHEW COBSTANTINE, DIRECTOR "O! PUBLIC HEALTH SERVICES "O!		"ONE VOICE"	CLAVDIA JOHAE, MD PUBLIC HEALTH OFFICER				
				/	ASSEMBLY INFO	ORMATION	
				MFG:	MODEL:	SIZE:	
WATER					REPLACEMENT		
PURPO	SE: METER		REPLACEMENT S	SERIAL #:			
ASSEMBLY LOCATION: FOR DETECTOR ASSEMBLY PAIRED WITH SERIAL #:							
Ł	FACILITY ID:	CONTACT:					
FACILITY	BUSINESS NAME:						
FA	SITE ADDRESS:						
, К	OWNER / CONTACT NA						
OWNER / MGMT	MANAGEMENT NAME (MAIL ADDRESS:	C/O):					
Ô	MAIL ADDRESS.						
DOUBLE CHECK VALVE ASSEMBLY TEST RESULTS INFORMATION							

		PRESSURE PRINCIPLE A	SSEMBLY	PRESSURE VACUUM BREAKER		
	CHECK VALVE NO.1	CHECK VALVE NO.2	DIFFERENTIAL RELIEF VALVE	AIR INLET VALVE	CHECK VALVE	
INITIAL TEST DATE	HELD AT: LEAKED	HELD AT: CLOSED TIGHT (RP) LEAKED	OPENED AT OPENED UNDER 2.0 PSID OR DID NOT OPEN	OPENED AT: OPENED UNDER 1.0 PSID OR DID NOT OPEN	HELD AT: PSID LEAKED	
R E P A I R	1) CLEANED REPLACED 2) DISC 3) SPRING 4) GUIDE 5) SEAT 6) MODULE 7) OTHER	1) CLEANED REPLACED 2) DISC 3) SPRING 4) GUIDE 5) SEAT 6) MODULE 7) OTHER	1) CLEANED 2) EXERCISED REPLACED: 3) DISC(S) 4) SPRING 5) DIAPHRAGM(S) 6) SEAT(S) 7) O-RING(S) 8) MODULE 9) OTHER	1) CLEANED REPLACED 2) DISC 3) DIAPHRAGM 4) FLOAT 5) OTHER	1) CLEANED REPLACED 2) DISC 3) MODULE 4) OTHER	
FINAL TEST DATE PASS FAIL	HELD AT: PSID LEAKED	HELD AT:	OPENED AT:	OPENED AT:	HELD AT: PSID	

COMMENTS:

The above certified to be true at the time of testing:	Proper Installation				
Tester Name:	Company Name:				
Certification No:	Address:				
Signature:	Phone No:				